

ELECTRICAL INSPECTOR'S MEETING NOTICE

WHEN: WEDNESDAY, APRIL 18th, 2012

**WHERE: THE TAVERN LOWRY
7401 EAST 1ST AVENUE
DENVER, COLORADO 80230
TIME: 11:45 A.M.**

Please remember, the NECA and IEC offices will only host the **Electrical Inspector's** and **one NECA Contractor Member**, and **one IEC Contractor Member** from each firm, all others must pay \$10. Please make your checks payable to NECA and mail to the Chapter Office, 363 South Harlan Street, Suite 205, Lakewood, CO 80226-3552.

MEETING AGENDA

Call to order
Introductions
Announcements
Review and Approval of Previous Meeting Minutes
IAEI Update
State Electrical Board Update
Utility Report
IEC Report
NECA Report
NEMA Report
UL Report
Jurisdiction Reports
Chairman's Comments
Field Problems
Adjournment

Please bring a copy of this agenda and the minutes with you to the meeting.

ELECTRICAL INSPECTORS MEETING MINUTES OF FEBRUARY 15, 2012
THE TAVERN LOWRY

- I CALL TO ORDER: 12:00 PM
- II INTRODUCTIONS: (see attached schedule)
- III MINUTES FROM PREVIOUS MEETING:

M/S approved as submitted.

- IV I.A.E.I.:

Visit our web site at <http://rocky.iaei.org/home.htm> for information regarding the Denver Co, Annual Meeting and Trade show March 15th & 16th, to feature 2011 NEC Changes Class. Ramada Inn, 10 East 120th Ave Northglenn, Co. (I25 and 120th Ave)

Additional events will be SOARES Grounding & Bonding classes at the following locations,

Greeley, Co. - April 27th, 2012 - NE Division Seminar
Greely Rec. Center, 651 10th Ave

Ft. Collins, Co. - May 4th, 2012 - NE Division Seminar
Larimer County Courthouse Office Building 200 West Oak

Colorado Springs, Co. May 25th, 2012 - Seminar
Pikes Peak Regional Building Department, 2880 International Circle 80910

Durango, Co. - June 1st, 2012- Seminar
Noble Building Room 130, Fort Lewis State College Durango Co.

Ft. Morgan, Co. - June 22nd, 2012- NE Division Seminar
Morgan Community College, Main Building, Founders Room 920 Barlow Rd.

Sterling, July 13th, 2012 - NE Division Seminar
Hays Student Center Room 230, Northeast Junior College 100 College Ave.

Burlington, July 27th, 2012 - Seminar
Burlington Community Center Conference Room, 340 South 14th St.

Grand Junction, August 17, 2012 - Seminar
Clarion Inn, 755 Horizon Dr. (Formerly Holiday Inn)
The Western Section Meeting & Event highlights can be seen at <http://iaei-western.org/>

- V XCEL:

www.xcelenergy.com;

Updates on installations at

<http://www.xcelenergy.com/staticfiles/xcel/Marketing/Xcel-Energy-Standard-For-Installation-and-Use.pdf>

Discussion of Temp/ Construction Service Meters by exception per Dave Wynkoop, will not be required to be of the Meter Socket Lever Bypass type at this time.

VI STATE:

Chief Inspector Steve Conrad announced Robert Brant was hired as the new electrical inspector for Park County; he can be reached at (303) 869-3453.

To date about 7 notices have been issued for lapsed licenses.

New Apprentice registration is required within 30 days and can be performed on-line at

<http://www.dora.state.co.us/electrical/apprentice.htm>

Access to your personal user account: www.dora.state.co.us/electrical/cc.

VII N.R.T.L.:

U/L:

Discussion of early April Training on Listing & Labeling and Short Circuit Ratings of Industrial Control Panels

The U/L hotline phone number is: 1-800-595-9844 with # 3 for the region. I-phone contact # is:

www.ul.connect.com.

Code authority home page: <http://www.ul.com/global/eng/pages/offering/perspectives/regulator/>

U/L Newsletter:

<http://www.ul.com/global/eng/pages/offering/perspectives/regulator/ultimateemail/>

ETL SEMKO:

No representation at the meeting.

Telephone: 720-271-0829. Fax: 503-626-7328. E-mail: jack.lawall@intertek.com

VIII I.E.C.:

Nothing new.

IX N.E.M.A.: No representation.

www.nema.org:

X I.B.E.W.: Local 68:

Discussed guidance to assist members with personnel account setup & navigating the state website.

XI FIELD PROBLEMS:

Discussion of Sections 210.8 (B) & 422.52 to review if these Installations are required to be “readily accessible”.

Discussion of Section 210.63 (Service Receptacle) as it applies to replacement AC at an existing multi-family dwelling. Majority Consensus would not require it at this time.

Discussion of Section 110.24(B): Maximum Available Fault current Label’s as required in other than dwelling units may exceed older service ratings. (Inspectors should review these conditions).

New service installations in other than dwelling units shall comply with this requirement.

Discussion of Sign contractor to provide a licensed electrical contractor for replacement sign.
Majority consensus on a replacement would inspect up to the required disconnecting means and 3rd
party Listing & Labeling.

XII N.E.C.A.

The April Inspector meeting will be at the Tavern Lowry.

XIV NEXT MEETING:

Wednesday, November 16, 2011
The Tavern Lowry

XV ADJOURNED:

Meeting adjourned.
Minutes taken by John Fernandez
Minutes submitted by John Fernandez